


On-site Wastewater Management Training Course


Primary Treatment

Septic Systems

Centre for Environmental Training 


Septic Tank

- Is the most common type of domestic primary treatment system
- Use can be traced back to about 1860 in France and about 1900 in Australia
- Current designs have changed little
- Septic systems and trenches provide the only form of wastewater treatment in many rural communities

Centre for Environmental Training 


Septic Tank

- Provides a quiescent environment in which wastewater can settle and clarify between a settled sludge layer (below) and a surface scum layer (above)
- Accumulated sludge is periodically removed
- Clarified effluent passes downstream to land application or further treatment

Centre for Environmental Training 

AS/NZS1546:1

- Details of septic tanks are provided in *AS/NZS1546:1 On-site domestic wastewater treatment units Part 1: Septic tanks*, which covers:
- Performance requirements and criteria
 - Design and fittings
 - Materials and testing

Centre for Environmental Training 

Septic Tanks

- Watertight, durable concrete, glass fibre reinforced resin or plastic tank




Source: Midwest Concrete



Source: Access Septic



Source: Everhard Industries

Centre for Environmental Training 

Septic Tanks


- Cylindrical, with vertical or horizontal axis, or rectangular in shape




Source: Grahams Concrete Pty Ltd



Source: Tumbly Bay Concrete Pty Ltd



Source: Hynds NZ

Centre for Environmental Training 

Baffles

- May include a partition or baffle divider to assist with hydraulic buffering and reduce carry-over of solids




Centre for Environmental Training




Septic Tank Access

- Inverted inlet and outlet fittings, with inspection openings above for access and pump-out



Source: Standards Australia



Source: BioSeptic

Centre for Environmental Training



Septic Tank Installation

- In ground, with top of tank at or just above ground surface to prevent stormwater ingress



Centre for Environmental Training



Risers

- If installed below ground a watertight riser is fitted to support access and inspection covers



Centre for Environmental Training



Ground Anchors

- May require ground anchors to prevent hydrostatic uplift



Centre for Environmental Training



Primary Treatment

A number of simple processes operate in a septic tank:

- Sedimentation
- Flocculation
- Flotation
- Anaerobic digestion
- Clarification

Centre for Environmental Training



Sedimentation

- Achieved by density settling in quiescent conditions
- Aided by the flocculation of suspended particles into larger aggregates
- Removes >60% of the suspended solids load
- Sludge or biosolids accumulates at base of tank

Centre for Environmental Training



Flotation

- Fats, oils, grease, surfactants and other low density materials rise to the surface and form a scum layer
- Scum retained in the tank by an inverted outlet pipe (tee) or baffle
- Scum layer precludes oxygen and creates anaerobic conditions which assists in the breakdown of organic solids

Centre for Environmental Training



Scum Layer or Crust



Centre for Environmental Training



Scum Layer or Crust



Centre for Environmental Training



Anaerobic Digestion

- Organic material retained at the base of the tank undergoes microbiologically facilitated facultative and anaerobic decomposition
- Organic material is converted to stable compounds and gases such as carbon dioxide (CO₂), methane (CH₄) and hydrogen sulphide (H₂S)
- Retained sludge comprised mainly of lignous material that is difficult to decompose and will continue to accumulate

Centre for Environmental Training



Clarification

- Settled and skimmed wastewater retained within the central portion of the septic tank
- Re-suspension of settled solids is minimised under quiescent conditions
- Tanks are appropriately sized to allow for maximum solids settling
- Effluent is drawn from the clarified liquid between the sludge and scum layers and discharged for further treatment

Centre for Environmental Training



Septic Tank

- Provides capacity for a minimum of 24 hours hydraulic residence time for daily flow
- Provides storage capacity for accumulated sludge
- Prevents scum from moving downstream
- Starts microbiological degradation to reduce BOD₅, pathogens and settled solids

Centre for Environmental Training



Septic Tank Capacity

All-waste septic tank capacities (AS/NZS1547:2012)

Persons	Bedrooms	Average daily flow (L)	Tank capacity
1 - 5	1-3	Up to 1,000L	3,000L
6 - 7	4	1,000 - 1,400L	3,500L
8	5	1,400 - 1,600L	4,000L
9 - 10	6	1,600 - 2,000L	4,500L

Source: Standards Australia Standards New Zealand

- Note tank size requirements for larger houses

Centre for Environmental Training



Sludge Accumulation

- Sludge in a residential all-waste septic tank accumulates at approximately 80L/person/year
- Pumpout interval is determined by tank capacity required for 24-hour residence time for daily load (varies from system to system)
- For example, a 3,000L septic tank provides 24-hour residence time for 1,000L daily load, plus up to 2,000L sludge and scum capacity i.e. 5 persons x 80L/person/year x 5 years

Centre for Environmental Training



Sludge Accumulation

Assess sludge and scum accumulation in a septic tank using either:

- Sludge Judge
- Sludge Depth Indicator
- Pressure sensor operated septic tank monitoring system

Centre for Environmental Training



Sludge Judge



Centre for Environmental Training



Sludge Depth Indicator



Centre for Environmental Training



Septic Tank Monitoring System

Comprises:

- Control Panel and Modem
- Tank Sensor
- Apparatus Controller
- Distribution Pit Sensors
- Flow Improvement Control System
- Central Data Repository and Management System



Centre for Environmental Training



Septic Tank Effluent Quality

Parameter	Untreated domestic wastewater	Primary treated effluent
BOD ₅	200 - 300 mg/L	~ 150 mg/L
Suspended Solids	200 - 300 mg/L	~ 50 mg/L
Total Nitrogen	20 - 100 mg/L	50 - 60 mg/L
Total Phosphorus	10 - 25 mg/L	10 - 15 mg/L
Faecal Coliforms	10 ³ - 10 ¹⁰ cfu/100mL	10 ⁵ - 10 ⁷ cfu/100mL

Source: NSW DLG

Centre for Environmental Training



Primary Treatment

- Capable of removing approximately 25-35% of the BOD₅ load and more than 60% of the suspended solids load in raw domestic wastewater
- Solids accumulate in the base of the septic tank and liquids are discharged for further treatment
- Floating material (scum) accumulates on the liquid surface and provides an air tight seal, creating anaerobic conditions

Centre for Environmental Training



Outcomes

- Moderate reduction in the TN load
- Slight reduction in the TP load
- Limited pathogen removal
- High bacterial counts remain in effluent
- Septic tank effluent not suitable for direct environmental discharge
- Secondary treatment using aerobic processes (AWTS or sand filter etc.) or further treatment in a soil based system is required

Centre for Environmental Training



Improving Septic Tank Performance

- Simplest way to improve the performance of a standard septic tank is to fit or retrofit the outlet with an outlet filter
- Filters of various designs are commercially available and can reduce the impacts of solids carry over to the land application area or secondary treatment system
- Should prevent discharge of solids >3mm particle size and achieve TSS <100mg/L
- Filters have a large surface area to limit clogging and reduce maintenance requirements
- However, they do require periodic inspection and cleaning

Centre for Environmental Training



Septic Tank Outlet Filters




Centre for Environmental Training




Fitting a Septic Tank Outlet Filter



Centre for Environmental Training 


Fitting a Septic Tank Outlet Filter



Centre for Environmental Training 

Cleaning a Septic Tank Outlet Filter




Centre for Environmental Training 

Outlet Filter Performance


Parameter	Concentration (mg/L)			% Improvement
	Typical ST effluent	Without effluent filter	With effluent filter	
BOD ₅	450	180	130	28%
TSS	503	80	50	38%
NH ₃ -N	41	40	40	0%
Org. N-N	29	28	28	0%
TKN-N	70	68	68	0%
Org. P-P	6.5	6	6	0%
Inorg. P-P	11	10	10	0%
TP	17	16	16	0%
Oil and grease	164	25	15	40%

Source: Crites & Tchobanogous 1998

Centre for Environmental Training 


References

- Care and maintenance of residential septic systems (2002) B3583, University of Wisconsin-Extension.
- Bounds, T.R., "Design and Performance of Septic Tanks," Site Characterization and Design of Onsite Septic Systems ASTM STP 901, M.S. Bedinger, A.I. Johnson, and J.S. Fleming, Eds., American Society for Testing Materials, Philadelphia, 1997.
- Stafford, D. and Whitehead J.H. 2005. *Septic Tank Outlet Filters*. In Patterson, R.A. and Jones, M.J. eds. On-site '05 Performance Assessment of On-site Systems. Lanfax Laboratories, Armidale, September 2005.

Centre for Environmental Training 

References

- Stafford, D. and Whitehead J.H. 2007. *Performance of Septic Tank Outlet Filters*. In Patterson, R.A. and Jones, M.J. eds. On-site '07 Innovation and Technology for On-site Systems. Lanfax Laboratories, Armidale, September 2007.

Centre for Environmental Training 

Septic Tank Calculations

Question 1.

A new three bedroom house is supplied with reticulated water and has a 3,000L septic tank installed on construction. Assume that five people occupy the house.

- (i) Calculate the daily hydraulic load based on a design hydraulic load of 150L/person/day.

- (ii) Calculate the detention time of effluent in the septic tank at the outset.

- (iii) If sludge accumulates at the rate of 80L/person/year, calculate the amount of sludge that will accumulate in one year.

Question 2.

An older three bedroom house is supplied with reticulated water and is occupied by three people. On inspection, it is determined that the septic tank is of 2,300L capacity, but the tank is half full of sludge.

- (i) Calculate the daily hydraulic load based on a design hydraulic load of 150L/person/day.

- (ii) Calculate the annual sludge accumulation based on a sludge accumulation rate of 80L/person/year.

- (iii) A minimum of 24 hours detention must be maintained in the tank at all times. Calculate the length of time remaining before a pumpout will be required.

Septic Tank Calculations

ANSWERS

Question 1.

- (i) Daily hydraulic load = $5 \times 150\text{L/person/day} = 750\text{L/day}$
- (ii) Septic tank volume = 3,000L
Daily hydraulic load = 750L/day
Detention time = $3,000\text{L} / 750\text{L/day} = 4 \text{ days}$
- (iii) Occupancy = 5 persons
Sludge accumulation rate = 80L/person/year
Annual sludge accumulation = $5 \text{ persons} \times 80\text{L/person/year} = 400\text{L/year}$

Question 2.

- (i) Daily hydraulic load = $3 \times 150\text{L/person/day} = 450\text{L/day}$
- (ii) Occupancy = 3 persons
Sludge accumulation rate = 80L/person/year
Annual sludge accumulation rate = $3 \text{ persons} \times 80\text{L/person/year} = 240\text{L/year}$
- (iii) Tank capacity = 2,300L
Daily hydraulic load = 450L
Volume of sludge in tank = $2,300\text{L} / 2 = 1,150\text{L}$
Volume available for further sludge accumulation = $1,150\text{L} - 450\text{L} = 700\text{L}$
Sludge accumulation rate = 240L / year
Maximum time remaining prior to pumpout $700\text{L} / 240\text{L/year} = 2.9 \text{ years}$